



وزارة الكهرباء والماء

Ref : : الإشارة :

Date: 8/7/2010 : التاريخ :

الموافق :

KG/SC/FNSH/L-000528

M/s. General Electric International Inc., (J. V. Leader),
1 River Road
Building 40, 3rd Floor,
Schenectady, NY 12345 - 6000
U. S. A

Attn: Project Manager , Sabiya Project, Kuwait

Dear Sirs,

Engineering, Procurement & Construction, Operation and
Maintenance of Combined Cycle Gas Turbine Project
at Sabiya Power Station
Contract No. MEW/C/4010-2009/2010
Sub:- Request for Approval of Steel doors (fire rated)

HHI SABIYA SITE		
DCC		
TEAM	ACT	INFO
PD		
PM		
CM		✓
PCM		
ADMN		
A/C		
PROG		✓
HVAC		
CIVIL		
ARCH		✓
E&I		
QA/QC		✓
PIPE		
MECH		
COMM		
HSE		
FILE		

This has reference to your letter No. GK/SC/FNSH/L-000779 dated June 15, 2010 on the captioned subject enclosed with following company profile and catalogue for (Fire rated) steel doors.

No.	Item (Brand Name)	Material Details	Manufacturer/supplier
1.	Steel door (fire rated) Ceco Doors	Fire rated door Door thickness 45mm Face sheet 1.2-1.5mm thick 3 hour fire resistant	France Metal Doors and Frames (Egypt) Al Sabbil National Co. Kuwait

We have no objection to your proposed steel door (fire rated) manufacturer and supplier to be used in the project, provided the contractor complies with the contract clause 2.10 concerning preference to national products.

However contractor to ensure that the type of door supplied shall conform to specification requirements clause 5C.12.6 for U value, sound transmission etc. and doors samples shall be submitted for each type of door with test certificates for final approval.

This is for your information and necessary action.



Yours faithfully,

UNDER SECRETARY
MINISTRY OF ELECTRICITY AND WATER

CC: M/s. General Electric International Inc.
Kuwait Free Trade Zone,
P.O. Box 64585, Shuwaikh (B)
70456 Kuwait.

HAMED H. ALKHALEDI
AUS (Oper & Maint.)
Power Stations & Dist Plants

P.O. Box No.12 & 54 Safat, 13001 Safat, KUWAIT - Phone: +965-25371000
Fax No.: +965-25371420 / 1 / 2